



ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ
ਨੰ. 1 ਫਰੀਦਕੋਟ, ਜ਼ਿਲਾ ਫਰੀਦਕੋਟ - 151203

email. sdesub1@gmail.com

ਵੱਲ

Principal,
SMD World's School,
V.P.O Kot Sukhia,
Distt. Faridkot

ਪੱਤਰ ਨੰ: 1205

ਮਿਤੀ: 21/09/2026

ਵਿਸ਼ਾ:- ਵਾਟਰ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਇਸ ਦਫਤਰ ਦੇ ਜੂਨੀਅਰ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਵਾਟਰ ਸੈਪਲ ਲਿਆ ਗਿਆ (ਰਿਪੋਰਟ ਨਾਲ ਨੱਥੀ ਹੈ) ਜੋ ਕਿ ਸਾਫ਼ ਸੁਥਰਾ ਅਤੇ ਪੀਣ ਯੋਗ ਪਾਇਆ ਗਿਆ ਹੈ। ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਸੈਨੀਟੇਸ਼ਨ ਵੀ ਚੈਕ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ ਸਾਫ਼ ਸੁਥਰਾ ਅਤੇ ਵਧੀਆ ਪਾਇਆ ਗਿਆ। ਉਕਤ ਦੇ ਆਧਾਰ ਤੇ ਆਪ ਨੂੰ ਇਹ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ਵਾਟਰ ਟੈਸਟਿੰਗ ਰਿਪੋਰਟ ਦੀ ਕਾਪੀ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ.1,
ਫਰੀਦਕੋਟ।


Chairman
Seth Sant Ram Thapar Mem.
Charitable Trust (Regd.)


Principal
SMD World School
Kot Sukhia (Fdk.)

Notorized English Translation of Water and Sanitation Certificate

To:

The Principal,
SMD World School,
V.P.O. Kot Sukhia,
Distt. Faridkot



Letter No.: 1205

Date: 21/09/2026

Subject: Regarding issuance of Water and Sanitation Certificate

With reference to the subject cited above, the Junior Engineer of this office collected a water sample from your school (the report is enclosed), which was found to be clean and fit for drinking.

In addition, the sanitation facilities of your school were also inspected, and these were found to be clean and satisfactory.

On the basis of the above findings, this Water and Sanitation Certificate is hereby issued to your school.

Water Testing Report In-charge
Executive Officer,
Jal Supply and Sanitation Department,
Sub-Division No. 1,
Faridkot



ATTESTED
TRUE TRANSLATED VERSION

VINOD KUMAR
NOTARY PUBLIC KOTKAPURA
App. by Govt. of India Regd. No. 3114

24 SEP 2026 24/9/26

DISTRICT WATER TESTING LABORATORY, FARIDKOT


Department of water supply and sanitation, Ghanaia Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

TEST REPORT						
Name & Address of Customer : SMD WORLD SCHOOL V.P.O. KOTSUKHIA, FARIDKOT SMD WORLD SCHOOL V.P.O. KOTSUKHIA, FARIDKOT			Customer Reference No.		No : SMD/1045/2026 Dated : 26/06/2026	
			Sample Submitted by		HARMOHAN SINGH	
			Date of Sample Receipt		26/06/2026	
			Analysis Starting Date		26/06/2026	
			Analysis completion Date		27/06/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		DWTL/FDK/2627/00067		Date of Issue :		27/06/2026
Registration no.:		DWTL/FDK/REG2627/00221		Condition of Sample :		Sealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		SMD WORLD SCHOOL V.P.O. KOTSUKHIA, FARIDKOT / NA
Village :		Kot Sukhia		Habitation :		Kot Sukhia
Block:		Faridkot		District :		Faridkot
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.28@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	40	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	48	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	18	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	BDL	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	22	250	1000	mg/l	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Faridkot

----- End of the Test Report -----


Seth Sant Ram Thapar Mem.
Charitable Trust (Regd.)


Principal
SMD World School
Kot Sukhia (Fdk.)

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com


TEST REPORT						
Name & Address of Customer : Principal SMD World School VPO- Kot Sukhia, Distt. Faridkot(Punjab)			Customer Reference No.		No : 1046 Dated : 26/06/2026	
			Sample Submitted by		Mr.Gurpreet	
			Date of Sample Receipt		16/09/2026	
			Analysis Starting Date		16/09/2026	
			Analysis completion Date		16/09/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :		Treated Water	
Test Report No.: RWTLASR/2627/00784			Date of Issue :		16/09/2026	
Registration no.: RWTLASR/REG2627/03593			Condition of Sample :		Sealed	
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)			Quantity/Type of Bottle:		750 ml / Transparent Glass Bottle	
Scheme/Source: Not Mentioned(Not Mentioned)			Location/Depth :		Kot Sukhia(RO) / NA	
Village : Not Mentioned			Habitation :		Not Mentioned	
Block: Not Mentioned			District :		Faridkot	
Latitude : Not Mentioned			Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	0.022	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	0.027	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	0.019	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	BDL(5)	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
12	Manganese(Mn)	BDL(0.005)	0.1	0.3	mg/l	APHA (24th Ed. 2023) Method :3125 B By ICPMS
13	Zinc(Zn)	0.010	5	15	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS

Continue on next page...

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar


Chairman
Seth Sant Ram Thapar Mem.
Charitable Trust (Regd.)


Principal
SMD World School
Kot Sukhia (Fdk.)

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.

rwtlasr1@gmail.com

14	Barium	0.026	0.7	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
----	--------	-------	-----	---------------	------	---

This Report is issued under the following terms & Condition :

1. The results relate to the sample tested as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

----- End of the Test Report -----



Chairman
Seth Sant Ram Thapar Mem.
Charitable Trust (Regd.)



Principal
SMD World School
Kot Sukhia (Fdk.)